

Lab ID	Date Received	Date Tested	Compression Machine	Load Cap	Cylinder A Diameter	Cylinder B Diameter	Cylinder C Diameter	A: PSI	B:PSI	C:PSI	WITHIN TEST AVG	RANGE	ACCEPTABLE VARIATION	AVERAGE RESULT	WITHIN TEST VARIATION RESULT	COMMENTS
11002	9/28/2009	10/12/2009	Forney	400000	4.04	4.04	4.04	8420	8580	8680	8560	260	483	ACCEPTABLE	ACCEPTABLE	
11004	9/28/2009	10/12/2009	Forney	400000	4.03	4.04	4.03	7830	7870	7910	7870	80	444	ACCEPTABLE	ACCEPTABLE	
11005	9/28/2009	10/12/2009	Forney	300000	4.04	4.04	4.04	8070	8080	7750	7970	330	450	ACCEPTABLE	ACCEPTABLE	
11006	9/29/2009	10/12/2009	Forney	400000	4.02	4.01	4.02	8670	8790	8980	8810	310	497	ACCEPTABLE	ACCEPTABLE	
11007	9/28/2009	10/12/2009	Forney	400000	4.02	4.03	4.03	8430	8540	8420	8460	120	477	ACCEPTABLE	ACCEPTABLE	
11008	9/29/2009	10/12/2009	Test Mark	300000	4.04	4.05	4.04	7780	7850	7490	7710	360	435	ACCEPTABLE	ACCEPTABLE	
11009	9/28/2009	10/12/2009	Forney	400000	4.05	4.05	4.07	7800	7810	7610	7740	200	437	ACCEPTABLE	ACCEPTABLE	
11010	9/28/2009	10/12/2009	Forney	400000	4.00	4.00	4.00	8740	8990	8920	8880	250	501	AVERAGE OUTSIDE ACCEPTABLE LIMITS	ACCEPTABLE	
11011	9/28/2009	10/12/2009	Forney	400000	4.03	4.04	4.04	8120	8150	7760	8010	390	452	ACCEPTABLE	ACCEPTABLE	
11017	9/28/2009	10/12/2009	Forney	250000	4.04	4.04	4.03	8210	8230	8250	8230	40	464	ACCEPTABLE	ACCEPTABLE	
11021	9/28/2009	10/12/2009	Forney	500000	4.03	4.03	4.03	8135	8139	7843	8040	296	453	ACCEPTABLE	ACCEPTABLE	
11022	9/28/2009	10/12/2009	Forney	500000	3.99	3.99	3.99	8250	8520	8060	8280	460	467	ACCEPTABLE	ACCEPTABLE	
11025	9/29/2009	10/12/2009	Forney	500000	4.00	4.00	4.00	9100	9040	8855	9000	245	508	AVERAGE OUTSIDE ACCEPTABLE LIMITS	ACCEPTABLE	
11029	9/28/2009	10/12/2009	Forney	500000	4.03	4.03	4.03	8270	8100	7800	8060	470	455	ACCEPTABLE	Within test variation outside acceptable limits	
11030	9/29/2009	10/12/2009	Forney	500000	4.00	4.00	3.99	8730	8590	8640	8650	140	488	ACCEPTABLE	ACCEPTABLE	
11034	9/29/2009	10/12/2009	Forney	400000	4.04	4.03	4.03	8140	8170	7920	8080	250	456	ACCEPTABLE	ACCEPTABLE	
11040	#####	10/12/2009	Forney	400000	4.01	4.02	4.01	7980	8000	8090	8020	110	452	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11042	9/29/2009	10/12/2009	Forney	400000	4.02	4.02	4.02	8390	8380	8570	8450	190	477	ACCEPTABLE	ACCEPTABLE	
11046	9/28/2009	10/12/2009	Test Mark	400000	4.06	4.05	4.04	7860	7870	8360	8030	500	453	ACCEPTABLE	Within test variation outside acceptable limits	
11048	9/28/2009	10/12/2009	Forney	400000	4.04	4.04	4.04	8040	7610	7730	7790	430	439	ACCEPTABLE	ACCEPTABLE	
11049	9/29/2009	10/12/2009	Brainard Kilman	340000	4.04	4.04	4.03	7910	7800	7840	7850	110	443	ACCEPTABLE	ACCEPTABLE	
11051	9/28/2009	10/12/2009	Forney	275000	12.79	12.79	12.85	7890	7730	8090	7900	360	446	ACCEPTABLE	ACCEPTABLE	
11052	9/28/2009	10/12/2009	Forney	500000	4.04	4.05	4.05	7840	7890	7820	7850	70	443	ACCEPTABLE	ACCEPTABLE	
11053	9/28/2009	10/12/2009	Test Mark	450000	4.04	4.03	4.04	8040	7690	7830	7850	350	443	ACCEPTABLE	ACCEPTABLE	
11055	9/29/2009	10/12/2009	Forney	500000	4.04	4.04	4.04	7780	7830	7560	7720	270	435	ACCEPTABLE	ACCEPTABLE	
11056	9/28/2009	10/12/2009	Forney	500000	3.92	3.91	3.92	8090	7970	7990	8020	120	452	ACCEPTABLE	ACCEPTABLE	
11059	9/28/2009	10/12/2009	Test Mark	300000	4.03	4.03	4.03	7912	7753	7822	7830	159	442	ACCEPTABLE	ACCEPTABLE	
11061	9/29/2009	10/12/2009	Tinius Olsen	300000	4.05	4.03	4.04	8290	8560	8040	8300	520	468	ACCEPTABLE	Within test variation outside acceptable limits	
11062	9/28/2009	10/12/2009	Lane	300000	12.63	12.69	12.63	8234	8471	8314	8340	237	470	ACCEPTABLE	ACCEPTABLE	
11064	9/28/2009	10/12/2009	Forney	350000	4.04	4.04	4.03	7700	7890	7910	7830	210	442	ACCEPTABLE	ACCEPTABLE	
11065	9/28/2009	10/12/2009	Forney	400000	4.04	4.05	4.04	8460	8490	8770	8570	310	483	ACCEPTABLE	ACCEPTABLE	
11069	#####	10/12/2009	Forney	400000	4.05	4.07	4.04	8250	8110	8330	8230	220	464	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11075	#####	10/12/2009	Forney	300000	4.03	4.04	4.04	8310	8120	8100	8180	210	461	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11082	9/28/2009	10/12/2009	Forney	500000	4.04	4.03	4.04	7530	8130	8120	7930	600	447	ACCEPTABLE	Within test variation outside acceptable limits	
11083	9/28/2009	10/12/2009	Forney	500000	4.04	4.04	4.04	7660	7910	7930	7830	270	442	ACCEPTABLE	ACCEPTABLE	
11084	9/29/2009	10/12/2009	Forney	400000	4.01	4.00	4.00	8320	8175	8105	8200	215	462	ACCEPTABLE	ACCEPTABLE	
11086	9/29/2009	10/12/2009	Forney	300000	12.69	12.69	12.69	7990	7780	7630	7800	360	440	ACCEPTABLE	ACCEPTABLE	
11088	9/28/2009	10/12/2009	Forney	400000	4.04	4.03	4.03	8240	7810	8010	8020	430	452	ACCEPTABLE	ACCEPTABLE	
11089	9/29/2009	10/12/2009	Test Mark	400000	4.03	4.03	4.04	8430	8250	8280	8320	180	469	ACCEPTABLE	ACCEPTABLE	
11090	9/28/2009	10/12/2009	Test Mark	500000	4.04	4.04	4.04	7320	7830	7880	7680	560	433	ACCEPTABLE	Within test variation outside acceptable limits	
11094	9/28/2009	10/12/2009	Forney	250000	4.05	4.05	4.04	8030	7860	7910	7930	170	447	ACCEPTABLE	ACCEPTABLE	
11096	9/28/2009	10/12/2009	Forney	500000	4.01	4.01	4.01	8350	8410	8750	8500	400	479	ACCEPTABLE	ACCEPTABLE	
11102	9/28/2009	10/12/2009	Test Mark	400000	12.81	12.82	12.82	7620	7530	7860	7670	330	433	ACCEPTABLE	ACCEPTABLE	
11105	9/28/2009	10/12/2009	Forney	600000	4.04	4.04	4.03	7800	7890	7870	7850	90	443	ACCEPTABLE	ACCEPTABLE	
11106	9/28/2009	10/12/2009	Test Mark	300000	4.05	4.04	4.04	8040	8190	8030	8090	160	456	ACCEPTABLE	ACCEPTABLE	
11108	9/29/2009	10/12/2009	Test Mark	400000	4.02	4.01	4.02	8100	8390	8710	8400	610	474	ACCEPTABLE	Within test variation outside acceptable limits	
11115	9/28/2009	10/12/2009	Forney	250000	4.04	4.04	4.04	8120	8080	8040	8080	80	456	ACCEPTABLE	ACCEPTABLE	
11119	#####	10/12/2009	Forney	250000	4.04	4.04	4.04	7940	8050	8120	8040	180	453	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11129	9/28/2009	10/12/2009	Forney	500000	12.82	12.88	12.82	7750	7810	7920	7830	170	442	ACCEPTABLE	ACCEPTABLE	
11135	9/28/2009	10/12/2009	Forney	250000	4.04	4.04	4.04	7780	7940	8120	7950	340	448	ACCEPTABLE	ACCEPTABLE	
11137	#####	10/12/2009	Forney	450000	4.00	4.00	4.00	8220	8530	8420	8390	310	473	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11143	9/29/2009	10/12/2009	Test Mark	300000	4.04	4.04	4.05	7900	8340	8510	8250	610	465	ACCEPTABLE	Within test variation outside acceptable limits	
11145	9/28/2009	10/12/2009	CM-216	330000	3.99	3.99	4.00	8730	8570	8570	8620	160	486	ACCEPTABLE	ACCEPTABLE	
11153	9/29/2009	10/12/2009	Forney	350000	4.03	4.03	4.04	8820	8910	9070	8930	250	504	AVERAGE OUTSIDE ACCEPTABLE LIMITS	ACCEPTABLE	
11158	9/28/2009	#####	Test Mark	500000	4.04	4.04	4.04	8820	8810	8830	8820	20	497	ACCEPTABLE	ACCEPTABLE	TEST DATE
11160	9/28/2009	10/12/2009	Forney	400000	4.01	4.03	4.03	9000	9100	9050	9050	100	510	AVERAGE OUTSIDE ACCEPTABLE LIMITS	ACCEPTABLE	
11165	9/28/2009	10/12/2009	Forney	500000	4.06	4.04	4.05	8030	8120	8110	8090	90	456	ACCEPTABLE	ACCEPTABLE	
11167	9/28/2009	10/12/2009	ACCU-TEK	500000	12.76	12.76	12.82	8640	8970	8410	8670	560	489	ACCEPTABLE	Within test variation outside acceptable limits	
11171	9/28/2009	10/12/2009	Forney	400000	4.03	4.04	4.03	8110	7780	7860	7920	330	447	ACCEPTABLE	ACCEPTABLE	
11173	#####	10/12/2009	Forney	500000	4.03	4.03	4.04	8190	7950	8330	8160	380	460	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11179	#####	10/12/2009	Forney	500000	4.05	4.05	4.05	8030	8220	8430	8230	400	464	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11183	9/28/2009	10/12/2009	Forney	250000	4.05	4.05	4.04	7960	7650	7880	7830	310	442	ACCEPTABLE	ACCEPTABLE	
11185	9/29/2009	10/12/2009	Humboldt	500000	4.03	4.03	4.05	8290	8590	8540	8470	300	478	ACCEPTABLE	ACCEPTABLE	
11186	9/28/2009	10/12/2009	Forney	300000	4.04	4.03	4.04	8220	8010	7830	8020	390	452	ACCEPTABLE	ACCEPTABLE	
11187	9/29/2009	10/12/2009	Test Mark	300000	4.06	4.04	4.03	8120	8200	8180	8170	80	461	ACCEPTABLE	ACCEPTABLE	
11190	9/29/2009	10/12/2009	Forney	500000	4.02	4.03	4.03	8700	8990	8810	8830	290	498	AVERAGE OUTSIDE ACCEPTABLE LIMITS	ACCEPTABLE	
11193	#####	10/12/2009	Test Mark	300000	4.02	4.03	4.01	8530	8340	8220	8360	310	472	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11204	9/28/2009	10/12/2009	Forney	450000	12.83	12.83	12.81	7780	7590	7850	7740	260	437	ACCEPTABLE	ACCEPTABLE	
11208	9/28/2009	10/12/2009	Test Mark	400000	4.04	4.04	4.04	8120	8000	8060	8060	120	455	ACCEPTABLE	ACCEPTABLE	
11212	9/28/2009	10/12/2009	Forney	500000	4.04	4.04	4.04	7520	7410	7750	7560	340	426	ACCEPTABLE	ACCEPTABLE	
11215	9/28/2009	10/12/2009	Forney	250000	4.04	4.04	4.04	8660	8410	8470	8510	250	480	ACCEPTABLE	ACCEPTABLE	

4" X 8"

CONCRETE CYLINDER DATA

2009 REPORT

											7880	500	444	ACCEPTABLE	Within test variation outside acceptable limits	
11232	9/30/2009	10/12/2009	Forney	400000	4.04	4.04	4.04	7970	7580	8080						
11235	#####	10/12/2009	Forney	500000	4.03	4.04	4.04	7710	8110	8010	7940	400	448	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
											8080	670	456	ACCEPTABLE	Within test variation outside acceptable limits	RECEIVED DATE
11237	#####	10/12/2009	Forney	250000	12.81	12.81	12.81	8320	8280	7650						
11240	9/28/2009	10/12/2009	Test Mark	400000	4.01	4.00	4.00	7960	7990	8010	7990	50	451	ACCEPTABLE	ACCEPTABLE	
11245	9/28/2009	10/12/2009	Forney	400000	4.04	4.05	4.04	8090	7900	7850	7950	240	448	ACCEPTABLE	ACCEPTABLE	
11247	9/28/2009	10/12/2009	Forney	125000	4.04	4.05	4.04	8000	8200	7890	8030	310	453	ACCEPTABLE	ACCEPTABLE	
11261	9/28/2009	10/12/2009	Forney	250000	4.04	4.03	4.03	8166	8249	8247	8220	83	464	ACCEPTABLE	ACCEPTABLE	
11271	9/28/2009	10/12/2009	Test Mark	300000	4.04	4.04	4.04	8060	8130	8030	8070	100	455	ACCEPTABLE	ACCEPTABLE	
											9240	330	521	AVERAGE OUTSIDE ACCEPTABLE LIMITS	ACCEPTABLE	
11277	9/29/2009	10/12/2009	Forney	250000	4.00	4.00	4.00	9390	9060	9280						
11311	9/28/2009	10/12/2009	Forney	400000	4.04	4.04	4.04	8270	8150	8030	8150	240	460	ACCEPTABLE	ACCEPTABLE	
											8870	70	500	AVERAGE OUTSIDE ACCEPTABLE LIMITS	ACCEPTABLE	RECEIVED DATE
11319	#####	10/12/2009	Forney	300000	4.04	4.04	4.03	8840	8910	8860						
11322	9/30/2009	10/12/2009	Forney	250000	4.01	4.02	4.01	8550	8290	8380	8410	260	474	ACCEPTABLE	ACCEPTABLE	
11330	9/28/2009	10/12/2009	Test Mark	400000	4.04	4.04	4.04	7970	7880	7650	7830	320	442	ACCEPTABLE	ACCEPTABLE	
11353	9/29/2009	10/12/2009	Forney	400000	4.04	4.04	4.04	8320	8480	8550	8450	230	477	ACCEPTABLE	ACCEPTABLE	
11358	9/28/2009	10/12/2009	Test Mark	300000	4.04	4.03	4.03	7944	8064	7839	7950	225	448	ACCEPTABLE	ACCEPTABLE	
11371	#####	10/12/2009	Forney	450000	12.71	12.68	12.71	8230	8390	7970	8200	420	462	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
											8100	990	457	ACCEPTABLE	Within test variation outside acceptable limits	
11376	9/28/2009	10/12/2009	Test Mark	300000	4.05	4.04	4.05	8470	8360	7480						
11379	#####	10/12/2009	Forney	250000	4.00	4.01	4.00	7780	7860	7840	7830	80	442	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11384	#####	10/12/2009	Forney	500000	4.06	4.08	4.06	8240	8360	8550	8380	310	473	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11385	9/29/2009	10/12/2009	Test Mark	300000	4.03	4.04	4.04	8060	7840	7910	7940	220	448	ACCEPTABLE	ACCEPTABLE	
11394	9/30/2009	10/12/2009	Test Mark	500000	12.82	12.82	12.82	8390	8570	8240	8400	330	474	ACCEPTABLE	ACCEPTABLE	
11402	#####	10/12/2009	Test Mark	300000	4.00	4.00	4.00	7980	8160	8160	8100	180	457	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11409	9/28/2009	10/12/2009	Brainard Kilman	250000	4.00	4.00	4.00	8440	8310	8670	8470	360	478	ACCEPTABLE	ACCEPTABLE	
											6570X	560	371	AVERAGE OUTSIDE ACCEPTABLE LIMITS	Within test variation outside acceptable limits	RECEIVED DATE
11411	#####	10/12/2009	E.L.E	350000	4.01	3.99	4.00	6500	6880	6320						
11413	9/28/2009	10/12/2009	Forney	250000	4.04	4.04	4.04	7920	7960	8000	7960	80	449	ACCEPTABLE	ACCEPTABLE	
11419	9/28/2009	10/12/2009	Forney	250000	4.05	4.06	4.05	8000	8030	7740	7920	290	447	ACCEPTABLE	ACCEPTABLE	
11431	#####	10/12/2009	Test Mark	300000	4.04	4.04	4.04	8250	8430	8080	8250	350	465	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11433	#####	10/12/2009	Test Mark	300000	4.04	4.04	4.04	8120	8290	8360	8260	240	466	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
11436	9/28/2009	10/12/2009	Test Mark	400000	4.03	4.03	4.03	8080	7780	7870	7910	300	446	ACCEPTABLE	ACCEPTABLE	
											7640	540	431	ACCEPTABLE	Within test variation outside acceptable limits	
11438	9/28/2009	10/12/2009	Forney	300000	4.04	4.03	4.03	7490	7450	7990						
11443	9/28/2009	10/12/2009	Test Mark	500000	4.06	4.05	4.06	7730	7680	7680	7700	50	434	ACCEPTABLE	ACCEPTABLE	
											9020	150	509	AVERAGE OUTSIDE ACCEPTABLE LIMITS	ACCEPTABLE	
11448	9/28/2009	10/12/2009	Forney	10000	4.01	4.00	4.00	9020	9090	8940						
11452	9/28/2009	10/12/2009	Forney	500000	4.04	4.04	4.05	7900	7800	7930	7880	130	444	ACCEPTABLE	ACCEPTABLE	
											7810	530	440	ACCEPTABLE	Within test variation outside acceptable limits	
11456	9/29/2009	10/12/2009	Test Mark	300000	4.03	4.04	4.04	7480	8010	7930						
11457	9/29/2009	10/12/2009	Test Mark	300000	4.01	4.01	4.02	8040	8060	8270	8120	230	458	ACCEPTABLE	ACCEPTABLE	
11459	9/29/2009	10/12/2009	Test Mark	300000	4.02	4.02	4.03	8460	8420	8500	8460	80	477	ACCEPTABLE	ACCEPTABLE	
11463	9/28/2009	10/12/2009	Forney	250000	4.03	4.03	4.02	8110	8180	8320	8200	210	462	ACCEPTABLE	ACCEPTABLE	
11469	9/28/2009	10/12/2009	Lane	250000	4.04	4.03	4.03	8210	7970	7820	8000	390	451	ACCEPTABLE	ACCEPTABLE	
11473	9/28/2009	10/12/2009	Test Mark	500000	4.04	4.03	4.04	7410	7640	7780	7610	370	429	ACCEPTABLE	ACCEPTABLE	
11474	9/28/2009	10/12/2009	Forney	400000	4.05	4.05	4.04	8220	8110	8140	8160	110	460	ACCEPTABLE	ACCEPTABLE	
11479	9/28/2009	10/12/2009	Forney	250000	4.05	4.04	4.04	8100	8120	8340	8190	240	462	ACCEPTABLE	ACCEPTABLE	
12002	9/28/2009	10/12/2009	Forney	600000	4.04	4.05	4.04	7960	8210	8040	8070	250	455	ACCEPTABLE	ACCEPTABLE	
12003	9/28/2009	10/12/2009	Forney	400000	4.01	4.00	4.01	8310	8220	8380	8300	160	468	ACCEPTABLE	ACCEPTABLE	
12004	9/28/2009	10/12/2009	Forney	400000	12.69	12.69	12.57	8300	8150	8210	8220	150	464	ACCEPTABLE	ACCEPTABLE	
12006	9/28/2009	10/12/2009	Forney	400000	4.02	4.02	4.02	8120	7690	7950	7920	430	447	ACCEPTABLE	ACCEPTABLE	
12011	9/29/2009	10/12/2009	Forney	600000	4.02	4.02	4.02	7990	7830	7820	7880	170	444	ACCEPTABLE	ACCEPTABLE	
12012	9/28/2009	10/12/2009	Forney	500000	4.04	4.04	4.04	7790	7850	7850	7830	60	442	ACCEPTABLE	ACCEPTABLE	
											7560	520	426	ACCEPTABLE	Within test variation outside acceptable limits	
12013	9/29/2009	10/12/2009	Forney	500000	4.01	3.98	4.00	7810	7290	7570						
12016	9/28/2009	10/12/2009	Forney	400000	12.81	12.81	12.81	8140	8130	8280	8180	150	461	ACCEPTABLE	ACCEPTABLE	
12020	9/28/2009	10/12/2009	Forney	300000	4.04	4.04	4.05	7810	7930	8160	7970	350	450	ACCEPTABLE	ACCEPTABLE	
12023	9/28/2009	10/12/2009	Forney	500000	4.04	4.04	4.04	7360	7560	7590	7500	230	423	ACCEPTABLE	ACCEPTABLE	
12035	9/28/2009	10/12/2009	Forney	400000	4.05	4.05	4.05	7830	8020	7740	7860	280	443	ACCEPTABLE	ACCEPTABLE	
12170	9/28/2009	10/12/2009	Forney	250000	4.03	4.03	4.03	8560	8509	8761	8610	252	486	ACCEPTABLE	ACCEPTABLE	
12197	#####	10/12/2009	Forney	400000	4.04	4.04	4.04	8080	8010	7980	8020	100	452	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
12241	9/28/2009	10/12/2009	Test Mark	250000	4.04	4.04	4.04	7870	7920	7940	7910	70	446	ACCEPTABLE	ACCEPTABLE	
12344	9/28/2009	10/12/2009	Forney	600000	4.03	4.04	4.04	7530	7760	7620	7640	230	431	ACCEPTABLE	ACCEPTABLE	
12425	#####	10/12/2009	Forney	500000	4.06	4.00	4.00	8090	8510	8500	8370	420	472	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE
12446	9/28/2009	10/12/2009	Forney	250000	4.02	4.01	4.03	8240	7990	8340	8190	350	462	ACCEPTABLE	ACCEPTABLE	
											8030	1070	453	ACCEPTABLE	Within test variation outside acceptable limits	
12479	9/29/2009	10/12/2009	Forney	250000	4.00	4.00	4.00	7560	7910	8630						
12517	9/28/2009	10/12/2009	Test Mark	400000	4.04	4.04	4.04	7950	8100	7910	7990	190	451	ACCEPTABLE	ACCEPTABLE	
12518	9/28/2009	10/12/2009	Test Mark	300000	4.04	4.04	4.04	7800	7730	7780	7770	70	438	ACCEPTABLE	ACCEPTABLE	
12525	9/28/2009	10/12/2009	Test Mark	300000	3.99	4.00	4.00	7990	8080	7960	8010	120	452	ACCEPTABLE	ACCEPTABLE	
13002	9/28/2009	10/12/2009	Forney	10000	4.00	4.00	4.00	8430	8390	8815	8550	425	482	ACCEPTABLE	ACCEPTABLE	
14071	9/28/2009	10/12/2009	Test Mark	400000	4.00	4.00	4.00	8050	7910	8140	8030	230	453	ACCEPTABLE	ACCEPTABLE	
15003	#####	10/12/2009	DGSI CC-300	300000	4.02	4.02	4.02	8190	8220	8440	8280	250	467	ACCEPTABLE	ACCEPTABLE	RECEIVED DATE

Average	8135
StDev	343
CoVAR	4%
+2sd	8821
-2sd	7449
+3sd	9164
-3sd	7106